



November 20, 2014

NOBLE COMPANY
RICHARD MAURER
7300 ENTERPRISE DRIVE
SPRING LAKE MI 49456

Re: Description: SAFING, CHLORINATED POLYETHYLENE
Manufacturer: NOBLE COMPANY
Product Name: NOBLESEAL COMPOSITE SHEET MEMBRANE
Model Number(s): NOBLESEAL TS
Product File No: 20140333

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (6) (f) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2019.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The installation of this product shall be in strict accordance with the manufacturer's printed installation instructions.
- All seams, seal penetrations, drains, terminal edges and preformed corners shall be sealed using NobleSealant 150.
- Nobleseal TS shall be bonded to the substrate using NobleBond EXT or latex modified thin set mortar that conforms to ANSI A118.4, or the appropriate standard, and TCNA Handbook recommendations.
- The installer shall be familiar with Noble Company's current written instructions, TCNA Handbook recommendations and ANSI A108 standard:

http://noblecompany.com/storage/docs/resources/NobleSeal_TS_Installation_Instructions_TS062014-04.pdf

<https://www.tcnatile.com/handbook-all.html>

<http://webstore.ansi.org/RecordDetail.aspx?sku=ANSI+A108%2FA118%2FA136.1%3A2013&sourcekeyword= inurl:webstore.ansi.org%23inurl:sku%3Dansi&source=google&adgroup=ANSI-Standards&gclid=CPSK5aGZisICFQiOaQodYkoAkw>

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail
SBD-10564-E (N.10/97)